

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2024/WZ/ 3)

Dated: 05/01/2024

To,

Sh. Shailendra Singh Bora,
M/s Sydney Grand Hotel & Resort,
Village Singhola, Main G.T.K.Road,
Delhi-110040.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Sydney Grand Motel & Resort and Just Chill Water & Fun Park located at Village Singhola, Main G.T.K. Road, Delhi- 110040.

Sir,

This has reference to your online application no. 2023121919702 dated 19/12/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building/ premise has been carried out by officer concerned of this department on 29.12.2023 to see the compliance of the requisite fire safety measures. Sh. Shailendra Singh Bora was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Basement, Ground & First floor. Your request for renewal of FSC is rejected as the following shortcomings were observed:

1. Fire check doors not provided at some locations.
2. Smoke management system in basement found provided but not functional.
3. First Aid Hose Reels provided but not functional.
4. Smoke/Heat detectors provided but not functional and also found removed at some locations.
5. MOEFA provided but not functional.
6. Public address system provided but not functional.
7. Yard hydrants provided but not functional in water park area.
8. Entire pumping system is not on auto mode.
9. Exit signage's found removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate. Till such time, FSC for renewal of Fire Safety Certificate is rejected.

Yours Faithfully

(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. The Joint Commissioner of Police (Lic.), 1st Floor, Police Station, Defence Colony, New Delhi.
2. MHA Portal ID No. 2023121919702 dated 19/12/2023.