



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/04

Dated: 05/01/2024

To

The Deputy Commissioner (Licensing)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Subject:- Online Application ID No.- 2023121119442 in r/o Adyar Ananda Bhavan Sweet India Pvt. Ltd.  
located at S-16, Green Park Street, Main Market, New Delhi-110016.

Sir,

This has a reference to online application ID No.- 2023121119442 dated 11.12.2023 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 29.12.2023 in the presence of Mr. Bala and observed that building comprised of Basement + Ground + 03 upper floors and terrace floor and following shortcomings were observed during inspection :

1. Width of rear side exit need to be increased to 1.5 mtr at each floor.
2. Hydrant not provided.
3. One fire pump capacity of 2280 LPM electrical, one capacity of 2280 LPM diesel and jockey 180 LPM not provided.
4. Overhead water tank capacity of 10,000 liter provided against required capacity of 1,00,000 liters.
5. Terrace floor also found fully constructed with temporary shed.

In addition to above the application needs correction in respect of number of staircase. Accordingly, the applicant may be directed to furnish correct information and compliance of above shortcomings for further necessary action for issuance of Fire Safety Certificate. **Hence application is rejected.**

Yours faithfully,

(Atul Gang)  
Director  
Delhi Fire Service

MS