

c/s7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/ 03
To

Dated: 03/01/2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s The Orient Guest House, Plot No A - 253/2
Road No -5, Mahipalpur Extn, New Delhi-110037.

Sir,

This has reference with your **MHA Portal ID No 2023111918650 dated 26/11/2023 & letter No 1324-25/Joint CP/Lic (H) dated 15/12/2023** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 02.01.2024 in the presence of Ms. Karuna of the Guest House. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The width of corridor is between 1.10 m to 1.48 m. The width of corridor shall not be less than of 1.50 mtr for single loaded and 1.80 mtr for double loaded as per clause 7.11.2 of UBBL 2016.
2. Smoke management system not provided in basement and upper floors.
3. Automatic sprinkler system not provided in basement.
4. The internal hydrants not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

9/1/24