



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No.F6/DFS/MS/Banquet/SZ/2024/ 05

Dated: 08/01/2024

To

The Dy. Health Officer,
Central Zone, Public Health Department,
South Delhi Municipal Corporation,
Shiv Mandir Marg, Lajpat Nagar, New Delhi

Sub:- Regarding renewal of Fire Safety Certificate in r/o M/s Kanak Banquet Hall (A Unit of PCP Caterers & Decorators) located at Ground floor, A-38, MCIE, Mathura Road, New Delhi-44.

Sir,

With reference to MHA online application ID no. 2023120519234 dated 07.12.2023 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 02.01.2024 in the presence of manager and it was observed that the banquet hall is running at ground floor of the building which is comprised of Basement + Ground + Mezzanine + 01 upper floor. During the inspection following shortcomings were observed:-

1. The submitted building plan does not match the site and there seen to be addition of area at ground floor.
2. Number & width of exits are not meeting the requirements.
3. The assembly area of the banquet shall be segregated from the kitchen by fire check door.
4. First-aid-hose reels found non function.
5. Manual operated electrical fire alarm system (MOEFA) found non functional.
6. Automatic sprinkler system found non functional in basement.
7. Internal hydrant system found non functional.
8. Fire pump found not functional.
9. Fire tanks shall not have domestic connections.
10. Combustible decoration at main entry shall be removed.
11. Exit signages found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station, Defence Colony, New Delhi.
2. The Owner/occupier/manager, M/s Kanak Banquet Hall (A Unit of PCP Caterers & Decorators) located at Ground floor, A-38, MCIE, Mathura Road, New Delhi-44.