

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SZ/School/2024/ 47

Dated: 08/01/2024

To

Dr. Aparna Mishra (Director),
Shri Banarsidas Chandiwala Sewa Samarak Trust Society,
Opp. Metro station sector-11 Dwarka New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Shri Banarsidas Chandiwala Sewa Samarak Trust Society, Located at Opp. Metro station sector-11 Dwarka New Delhi.

Sir,

Please refer to your letter No. BCIPS/Admin/F.No-164/2023-24/322, dated 11/12/2023 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officers concerned of this department on 03/01/2024 in the presence of Dr. Aparna Mishra (Director) from fire safety point of view.

The following shortcomings were observed during the time of inspection:-

1. Fire check doors / door closers found removed at some places.
2. Electric panel installed below the staircase must be shifted way from stairs or segregated and protected by Fire Check Door.
3. Terrace Pumps found nonfunctional in auto mode.
4. Dully fill form J & School details form are not submitted.

In view of the above shortcomings, renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. Directorate Of Education Old Secretariat Delhi – 110054.