

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/Educational/2024/SZ/ 62

Dated: 11/01/2024

To,

Executive Engineer (Bldg) MCD,
Civic Centre, Minto Road,
New Delhi-110002.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Property No. A-1/35, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter No. Nil, dated 22/11/2023, received in this department vide outdoor diary No. 9032 dated 22/11/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Mr. Kharbanda was present and it was observed that the building is comprised of Basement (Class rooms) Stilt (Parking), ground, First & Second floors (Coaching centre) and have following shortcomings:-

1. Door size of class room .92 m provided in place of 1.20.
2. Fire Check doors not provided.
3. Smoke Management/ventilation system not provided in basement.
4. Sprinkler System not provided in stilt area.
5. Underground water Tank & fire pumps as per IS 15105 not provided
6. Exit signage's are provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

9/1/24

Copy to:-

The Manager, Property No. A-1/35, Janakpuri, New Delhi-110058.