

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 14

Dated:- 10 / 01 / 2024

To

The Dy. Health Officer (Green Park Zone),  
Public Health Deptt, MCD,  
Green Park, New Delhi-110016

Sub: - Regarding issuance of fire safety certificate in r/o **M/s Ajit Khalsa Dhaba** located at **Ground Floor only**, 619/10, Main Road, Chhattarpur, Opp Tivoli Resort, New Delhi-110074

Sir,

This has reference to your **MHA Portal ID 2023121919716** dated 19/12/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 04.01.2024 in the presence of Mr. Paramjit Singh to verify the fire safety measures installed in the building and observed that the restaurant is running at Ground and first floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Terrace level pumps capacity 450 LPM provided but not found on auto mode.
2. Overhead tank capacity 10,000 ltrs provided against the required capacity 20,000 ltrs and the fire fighting tank also being used for domestic purposes.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

dm