

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2024/SZ/ 13
To

Dated 10/01/2024

The Dy. Health Officer,
Public Health Department, MCD,
Central Zone, Lajpat Nager,
New Delhi 110024.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Mandem (Unit of Interbix Club House Pvt Ltd) Situated at S-1, **Ground Floor, (Left Part Portion)**, Eros Hotel American Plaza Nehru Place, New Delhi 110019

Sir,

This has reference to with **MHA Portal ID 2023122219855 dated 22/12/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02.01.2023 in the presence of Mr. Nishant to verify the fire safety measures installed in the building and observed that restaurant running at Ground Floor only. During inspection, following points were observed:

1. First aid hose reel not working.
2. Detector system not working.
3. MOEFA not working.
4. Sprinkler system not working.
5. Hydrant not working.
6. Exit Signage found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

or