

c/53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/NDZ/2024/ 15

Dated: 10/01/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Moti Mahal Restaurant located at 3704, Netaji Subhash Marg, Daryaganj, Delhi- 02.

Sir,

This has reference to online application ID No. 2023112918992 dated 20.12.2023 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.01.2024 in presence of Mr. Anil (Manager) and it was observed that building is comprised of ground floor only. During inspection, following shortcomings were observed:

1. First aid hose reels found not functional.
2. Smoke detectors found removed.
3. MOEFA provided but not functional.
4. Exit signages are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service Ok
Tel: 01123414000

8/01

Copy to:-

The Manager,
M/s Moti Mahal Restaurant at 3704, Netaji Subhash Marg, Daryaganj, Delhi - 02.