

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/EH/ 18

Dated 11 /0 /2024

To

The Joint Commissioner of Police/Lic, 1st Floor, Licensing Unit, Police Station Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Cocopots Bakers located at Shop No. D-50, Ground Floor, Kamla Nagar, Delhi-110007.

Sir.

This has reference to online mha portal I'd No. 2023122719941 dated 28.12.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 08.01.2024 in the presence of Mrs. Taranoom Sethi (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has been observed that the building/ premise is comprised of basement, ground & 03 upper floors but (Restaurant running at ground floor only). Your request for FSC is rejected under Rule 35 (3) due to following shortcomings.

1 There are two exit doors provided in the restaurant and second exit door is obstruct by dee freezer & almirah.

2 Smoke ventilation found removed.

3 First aid hose reel hose provided but not functional & damaged condition.

4 Internal hydrants provided but not functional & one hose missing.

5 MOEFA system provided but not functional.

- 6 Terrace level fire pumps capacity of 450lpm provided but not functional & damaged condition.
- 7 Terrace level fire water tank capacity of 10,000ltrs provided but empty and 10,000ltrs found removed at site.
- Standby power supply not provided in the restaurant.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

Ph: 011-2341400