



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/EH/2024/ 23

Dated: 12/01/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s. House of Royal (A unit of Greeting Hospitality), Located at Shop No: - 2, 4<sup>th</sup> floor, Vishal, Rajouri Garden, New Delhi-110027.

Sir,

Please refer to your online application no. 2023121919706 dated 28/12/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 09/01/2024 in the presence of Mr. Vedant (Fire Officer Mall) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said restaurant is running at fourth floor in a building comprised of two basement, ground plus five upper floors. Fire safety arrangements such as Fire Extinguishers, Smoke Management system, First Aid Hose Reels, Automatic fire detection and alarming system, Internal Hydrants, Pumping Arrangements etc provided. However the following shortcomings were observed.

1. Automatic fire detection and alarming system is provided but not functional.
2. MOEFA is provided but not functional.
3. Exit signages is not provided.

In view of above Shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully,

  
Atul Garg  
Director

Copy to: -

1. The Owner/Occupier, Ms House of Royal (A unit of Greeting Hospitality), Located at Shop No: - 2, 4<sup>th</sup> floor, Vishal, Rajouri Garden, New Delhi-110027. (online application no. 2023121919706 dated 28/12/2023)
2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. ([dhowest\\_zone@gmail.com](mailto:dhowest_zone@gmail.com)).