

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No: F.6/DFS/MS/2024/WZ/ 69

Dated: 11/01/2024

To,

Sh. Ajay Kishor,  
Re Sustainability IWM Solutions Limited,  
Sector-5, DSIIDC Bawana, Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Re Sustainability IWM Solutions Limited, TSDF for Hazardous Waste at Sector-5, DSIIDC Bawana, Delhi-110039.

Sir,

This has reference to your e mail id dated 23/12/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said industrial building has been carried out by officer concerned of this department on 02.01.2024 in presence of Sh. Ajay Kishor to verify the fire safety arrangement provided there in.

During the course of inspection it was observed that the building comprised of Ground Floors and Ground plus first floor. Your request for issuance of FSC is rejected as the following shortcomings were observed:

1. Width of staircase found 1.50 m & 1.10 m against the required width of 1.50 m each.
2. Fire check doors found not provided.
3. Smoke/ Heat detectors not provided at some locations.
4. P.A. System found provided but not functional.
5. Pumping system is not on auto mode.
6. Exit signage's found not provided at some strategic locations.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Atul Garg