

2/43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ GH | 14

Dated:-..!./..!./2024

To,

The Manager
M/S SAI MIRACLE Guest House,
2532/10 & 11, Chuna Mandi,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S SAI MIRACLE Guest House located at 2532/10 & 11, Chuna Mandi, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2023122319859 dated 23/12/2023. on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 04/01/2024 in the presence of **Manager** and following shortcomings were observed:-

1. Smoke management system not provided as per gazette notification 27.05.2019.
2. Stand by power supply is not provided.

In view of above, the case is rejected with a request to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :

1. The Addl. Commissioner of Police - licensing, Defence colony Police Station , New Delhi