

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
Connaught Place: New Delhi-110001

No. F.6/DFS/MS/2022/BP/ 120

Dated : 08/06/2022

To,

The Chief Architect,
Central Public Works Department,
Nirman Bhawan
New Delhi.

Subject: Clearance of building plans from fire safety point of view in r/o Proposed Administrative Block for IGNOU at Maidangarhi, New Delhi - 110068.

Sir,

Please refer your ID No. Region Delhi Sub Region 20220408/2303 dated 30.05.2022 on the above cited subject. In this connection, this is to inform you that the building plans have been examined from fire / life safety point of view and following shortcomings are observed:

1. Complete set of architectural plans including site plan, key plan are not submitted in CAD format.
2. Smoke management plans are not submitted.
3. Information on CAF are not matching with plans.

In view of above, the case can not be scrutinized at this stage, hence rejected.

Yours faithfully,

(Axul Garg)
Director

011 23414000

Axul Garg