GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI- 110001

F.6/DFS/MS/Ind./2024/SZ/ 88 No.

Dated: 15/01.../2024

To

M/s Alankrit Handicrafts Pvt Ltd., 208, Okhla Industrial Area Phase- III,

New Delhi 110020

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Alankrit Handicrafts Pvt Ltd., 208, Okhla Industrial Area Phase- III, New Delhi 110020.

Sir,

This has reference to letter received through Outdoor diary no 11369 dated 29-12-2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.01.2024 in the presence of Mr. Shivakant Jha (Admin) to verify the fire safety measures installed in the building and observed that the industrial is running at 02 tier Basement, Ground plus two upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Check door found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg) SDMC Jal Vihar, Lajpat Nagar, New Delhi