



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/Hospital/2024/SZ/95

Dated 15/01/2024

To

Mr. Suneet Marwah,  
Chief Administrative Officer,  
Indian Spinal Injuries Center,  
Sec- C Vasant Kunj, New Delhi 110070

**Sub:** -Regarding issuance of Fire Safety Certificate in r/o Indian Spinal Injuries Center, at Sec- C Vasant Kunj, New Delhi 110070.

Sir,

This has reference with letter received through Email dated 22/09/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 08.01.2024 in the presence of Mr. Jagdish Singh (AGM) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

- 1 Detection system in some position not working.
- 2 Fire Check Door closing device found removed at some places.
- 3 Exit door at one staircase found 1.1mtr by creating of wall.
- 4 Some Tempary portion inside the building needs to be removed.
- 5 Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE