

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 27  
To

Dated 16/01/2024

The Dy. Health Officer, MCD,  
Public Health Officer,  
Aurobindo Marg, Green Park,  
New Delhi 110016

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s California, A Unit of Burrito Restaurants Pvt Ltd, F-38, GF, East of Kailash, Delhi 110065

Sir,

This has reference to with **MHA Portal ID 2023122219821 dated 22/12/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 11.01.2024 in the presence of Mr. Pawan Kumar (Manager) to verify the fire safety measures installed in the building and observed that restaurant is running at Ground Floor only. During inspection, following points were observed:

- 1 There are two exits provided in the restaurant having width of 1.5m & 1.0m against the required width of 1.5m each.
- 2 First aid Hose Reel provided but found non-functional.
- 3 Internal Hydrants provided but found non-functional.
- 4 Electric Fire Pump capacity 450 lpm provided but found non-functional.
- 5 Terrace level fire fighting water tank provided 5,000 ltrs against the requirement of 20,000 ltrs capacity.
- 6 Exit signage not provided.

The same observations has already been issued and communicated earlier by this department vide letter of even no 582 dated 26/10/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

