



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 14

Dated: 27/01/2024

To

The Principal,
Sri Ram Shiksha Vidyalaya,
Plot No. 357, Village Kapashera,
New Delhi-110037

Sub: Regarding renewal of Fire Safety Certificate in r/o Sri Ram Shiksha Vidyalaya located at Plot No. 357, Village Kapashera, New Delhi-110037

Sir,

This has reference to your letter received through outdoor diary no. 10981 dated 19/12/2023, on the subject cited above. In this connection, the said school premises was visited by the officer concerned of this department on 03/01/2024 to verify the availability and operability of the fire protection measures provided therein, in the presence of Ms. Praveen Yadav (Manager). During the course of inspection, the shortcomings observed are as below.

1. The hose-reel hose found non-functional i.e. leaking badly.
2. The terrace pump was not on auto mode.
3. The exit signage found removed at some places.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
0/21

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054