

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2024/WZ/ 119

Dated: 19/01/2024

To,

Mr. Rajesh Jain (President),
Adhayatamik Sanskriti Sewa Mission,
CSC-10, Block-H, Sector-15, Rohini,
Delhi-85.

Sub: Issue of FSC in r/o M/s Adhayatamik Sanskriti Sewa Mission, CSC-10, Block-H, Sector-15, Rohini, Delhi-85.

Sir,

This is in reference to your letter No. nil dated 12.10.2023 received through outdoor diary no. 7324 dated 13.10.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 19.12.2023, in presence of **Mr. N. K. Jain** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of Staircase is 1.08 mtr against the required width of 2.0 mtr.
2. The width of corridor is 1.7m & 2.5m against the required width of 2.40mtr.
3. The width of door is 1.07 & 1.20 mtr against the required width of 2.0 mtr.
4. Smoke ventilated is not provided in basement.
5. Public Address System is not provided.
6. Number of pumps at ground level and terrace are not provided as per guidelines issued.
7. Underground tank capacity of 1,00,000 ltrs not provided.
8. Inspection ladder for terrace tank is not provided.
9. The required exit signage are not provided.
10. Lift lobby and pressurization is not provided & Fire Man switch is not provided.
11. Standby power supply not provided.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully

(Aful Garg)
DIRECTOR

PH: 011-23414000