



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C/96.

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/21

Dated:- 19/01/2024

To,

The Principal,
Govt. Co-ed. Sr. Sec. School (ID-1617029),
Bakkarwala, New Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Co-ed. Sr. Sec. School (Old Building) (ID-1617029), located at Bakkarwala, New Delhi-110041.

Sir,

Please refer to your email dated 14/12/2023 on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 15/01/2024 in the presence of Sh. Suresh Kaushik (PGT Teacher). During inspection, it has been observed that the school building is comprised of 02 blocks - Ground + 01 upper floor. However, the following shortcoming has been observed:-

1. ABC & CO₂ type of Fire Extinguishers found non-functional in each block.
2. Electrical meters/panels found under the staircases same shall be shifted on another safe place.

In view of the above, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours Faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi 110054.