

c/77

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/SZ/2024/ 24

Dated:- 19/01/2024

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s. Hotel Pablas International, 12A/22, WEA, Karol Bagh, New Delhi- 110005.

Sir,

Please refer to online application ID 2023123020037 dated 01.01.2024 on the subject cited above. In this connection it is to inform you that the above building (Hotel) was inspected by the officer concerned of this department from safety point of view on 16.01.2024 in presence of Mr. Sandeep Sharma, (Manager).

During the course of inspection the following shortcomings have been observed:-

- 1 Wooden door are found installed in place of Fire Check Doors. The FCD of 01 hrs fire rated must be installed & certificate of the same must be submitted.
- 2 Detectors found nonfunctional.
- 3 Smoke ventilation system found not provided.
- 4 MOEFA found nonfunctional.
- 5 P.A system found not nonfunctional
- 6 Terrace pump capacity 450 LPM is provided but not functional in auto mode.

Keeping in view of above, fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter.

Yours faithfully

(Atul Garg)

Director

Ph: 011-23414000

Copy to:-

1. Sh. Harinder Singh (Owner),  
M/s. House No. 3875, Gali No-25,  
Reghar Pura, karol Bagh, New Delhi- 110005.
2. The Executive Engineer (Building), North MCD, Karol Bagh, Anand Parbat, New Delhi.