



c-09



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2024/School/ 33

Dated: 30 / 01 / 2024

To

The Principal  
Apex Public School,  
At B-Block, Sant Nagar,  
Burari, Delhi-110084

Sub: - Regarding grant of fire safety certificate in r/o Apex Public School (New Building) located at B-Block, Sant Nagar, Burari, Delhi-110084.

Sir,

Please refer to your letter No. SDJPS/01 dated 20.07.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 16.01.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of new building, ground & 02 upper floors only. At the time of inspection Dr. Derek Richard Brendish (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. There is two staircase provided width of 02m & 1.50m the second staircase of 02m provided for assembly hall is ground to first floor only and needs to be continues from ground to terrace level.
2. The door size for assembly hall 1.50m provided against the requirement of 02m.
3. Hose reel hose provided but not functional.
4. MOEFA system not provided.
5. Internal hydrant provided but not functional.
6. Terrace level fire pumps capacity 450lpm provided but not functional.
7. Terrace level fire water tank capacity 5,000ltr provided against the requirement of 10, 000ltr.
8. Exit signage's not provided at strategic location in the school building.
9. Standby power supply not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

  
(Anil Garg)  
Director

Ph: 011-23414000

24/11 9/11/24

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.