

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Business/2024/SZ/141

Dated: 24/01/2024

To

The Authorized Signatory,
Bajaj House,
Plot No 97, Nehru Place,
New Delhi 1100019.

Sub: Issuance of Fire Safety Certificate in r/o M/s Bajaj House, Plot No 97, Nehru Place, New Delhi 1100019

Sir,

This is in reference to with Letter No nil dated 11/12/2023, received through outdoor diary no 10784 dated 12/12/2023 on the subject cited above. This is to inform you that the premise was inspected by the concern nominated authority of this department on dated 15-01-2024 in presence of Mr. Vivek Kumar & observed that the building is comprised of Basement, Ground + Mezz. + Five upper floors. During the course of inspection, the following shortcoming observed were noticed:-

1. The Access to building is being used by unauthorized parking, which needs to be cleared.
2. Fire fighting pumps are not on auto mode.
3. Exit signage found removed at some places.
4. Electrical meter installed under/inside the staircase is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg) MCD, Jal Vihar, Lajpat Nagar, New Delhi 110024