

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**



c-12

NO. F.6/DFS/MS/EH/SZ/2024/ 41

Dated: 25/01/2024

To,

The Manager,  
M/s. Costa Coffee (A Unit of Devyani International Ltd.),  
E-14, Ground Floor, Shop No. 5, Major Sudesh Chandra Marg,  
Rajouri Garden, New Delhi- 110088.

Sub: Regarding issuance of fire safety certificate in r/o M/s. Costa Coffee(A Unit of Devyani International Ltd.), E-14, Ground Floor, Shop No. 5, Major Sudesh Chandra Marg, Rajouri Garden, New Delhi-110088.

Sir,

Please refer to online application ID 2024010900249 dated 10.01.2024 on the subject cited above. The above said eating house/restaurant running at ground floor of a building comprised of basement, stilt, ground plus three upper floors. The above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on the dated 19.01.2024 in the presence of Sh. Tarandeep Singh (Manager).

During the course of inspection the following shortcomings have been observed:-

1. Two exit doors found provided with width 1.20 & 1.0 mts. against requirement of two exit doors having width of 1.50 mts. each.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service