

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/135

Dated: 23/01/2024

To

The Authorized Signatory,
Devika Estate Management Pvt Ltd,
Devika Tower, 6 Nehru Palaces,
New Delhi 110019

Sub: Regarding Renewal of Fire Safety Certificate in r/o M/s Devika Tower, located at Plot No 06, Nehru Place, New Delhi 110019.

Sir,

This has reference with letter no nil dated 25/11/2023, received through outdoor diary no 10111 dated 28/11/2023 on the subject cited above. In this concretion it is to inform you that the premise was inspected by the concern officers of this department on 15-01-2024 in the presence of Mr. Dinkar Giri & observed that the building is comprised of Basement, Ground plus 15th Floors. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check door found removed at some places.
2. First aid hose reel provided but found nonfunctional.
3. Automatic sprinkler system provided but found nonfunctional.
4. Internal hydrant provided but found nonfunctional.
5. Fire fighting pumps provided but not on auto mode.
6. Exit signage found removed at some places.
7. Electrical meter installed under/inside the staircase is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Arun Garg)
Director
Delhi Fire Service

om