



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

Dated: 23 / 01 / 2024

No. F6/DFS/MS/NDZ/2024/ 136

To,
Mr. Subhash Kumar,
Dr. B. R. Ambedkar National Memorial Complex,
26, Alipur Road, Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Dr. B. R. Ambedkar National Complex, 26, Alipur Road, Delhi.**

Sir,
This has reference to your letter outdoor diary no. 11110 dated 21.12.2023 on the subject cited above. In this connection, it is to inform you that the building/ premises was visited by the officer concerned of this department on dated 08.01.2024 in the presence of Mr. Lokesh Meena (Supervisor) and it was observed that the building is comprised of 03 Basements + Ground + 01 upper floor. During inspection, following shortcomings were observed:

1. MOEFA provided but not functional.
2. Public address system provided but not functional.
3. Fire pump not in auto start mode.
4. Exit signages & lift signages are not provided.
5. Diesel pump (Stand by) is not working.

In view of above shortcomings, the occupancy of the building /premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.
The owner/ occupier is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel:-011-23414000

Copy to:-
The Executive Engineer (EI),
Development Project Electric Division, CPWD, IP Estate, New Delhi - 02.