

434

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2024/30

Dated: 24/01/2024

To,

The principal,  
Govt. Sr. Sec. School,  
Sector-3, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o Govt. Sr. Sec. School, Sector-3, Rohini, Delhi-110085. School ID-1413002.

Sir,

This is in reference to your letter No. SV/Sec-3/ROH/2023/793 dated 12.12.2023 received through outdoor diary no. 10834 dated 14.12.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **15.01.2024**, in presence of **Mr. O. P. Meena (In-charge)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Terrace Fire pump with capacity 450 lpm & auto starting/Manual stopping system of pumps provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt](http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt)  
[p://www.delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](p://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)

Yours faithfully

(Atul Garg)  
DIRECTOR

Ph; 011-23414000

DL  
my