

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2024/ 152

Dated 25.1.2024

To,

The Assistant Engineer (E), HC-4,
Health Maint. Elect. Division (Central),
PWD, Maulana Azad Medical College,
New Delhi - 110002.

Sub: Regarding renewal of Fire Safety Certificate for Guru Nanak Eye Centre, New Delhi.

Sir,

This has a reference to letter no. 23(fire)/AE(E)/HMED(central)/HC- 4,PWD/2023- 24/184 dated 20/12/2023, on the subject cited above. In this regard, this is to inform you that the site was inspected by officers concerned of this department on 15/01/2024 in the presence of Sh. Sandeep Panwar, JE (E) and following shortcomings were observed: -

1. Staircase of main block found blocked by dumping of waste material & almirahs.
2. Temporary office is constructed in lift lobby required to be removed.
3. Detectors found nonfunctional in ward block and panel found non-working.
4. PA system found nonfunctional.
5. Corridor found encroached by dumping of old furniture which may create hundle at the time of any emergency for easy evacuation.

In view of above, the case is rejected and fire safety certificate (FSC) cannot be issued at this stage.

Yours faithfully


(Atul Gang)
DIRECTOR
01123414000

Copy to:-

1. The Director, GNEC, New Delhi.
2. Executive Engineer (E), HMED (Central), PWD, Lok Nayak Hospital, New Delhi.
3. Junior Engineer (E), HC-4, HMED (C), PWD, GNEC, New Delhi.