

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2024/SZ/ 3 B  
To

Dated 24 / 01 / 2024

The Dy. Health Officer,  
Public Health Department, MCD,  
Aurobindo Marg, Green Park,  
New Delhi 110016.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s H AND H DRIVE INN located at Shop No 8, Community Centre, East of Kailash, New Delhi 110065.

Sir,

This has reference to with MHA Portal ID 2023112218789 dated 28/12/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 18.01.2024 in the presence of Ms Bhawna (Manager) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. There is one staircase having width of 1 mtr against the required two staircase having width of 1.50 mtr each.
2. There is one exit door having width of 1 mtr against the required two exit door having width of 1.50 each.
3. Fire check not provided at first floor for segregated the kitchen.
4. First Aid Hose reel hose not provided.
5. MOEFA provided not provided.
6. Internal hydrants not provided.
7. Terrace level pump capacity 450 LPM not provided.
8. Overhead tank capacity 20,000 ltrs not provided.
9. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE