



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001**

No. F6/DFS/MS/WZ/2024/ 137

Dated: 23/01/2024

To,

The Authorized Signatory,  
Multi level Parking with Commercial Development,  
Rajouri Garden Metro station,  
New Delhi-110027.

**Sub: - Regarding Renewal of FSC in r/o Multi level Parking with Commercial Development, Rajouri Garden Metro station, New Delhi-110027.**

Sir,

Please refer to your Letter No.- SGCPL/DPCC/RG/23/10 dated 22/12/2023, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 10/01/2023 in the presence of Ms. Sonia Sharma to check the functioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the said Mall is comprised of 03 Basement + Ground + 05 Upper Floor (Mezzanine & Foyer Level), was issued FSC by this department vide letter no. F6/DFS/MS/MN/2021/47 dated 22/01/2021. Fire Safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, Pumping Arrangements, Smoke Management System, MOEFA, Internal Hydrant, overhead water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. Smoke management system in basement is provided but not functional.
2. First -Aid Hose Reels is provided but found damage at some places.
3. MOEFA is provided but not functional.
4. Exit Signages is found removed at some places.

In view of above Shortcomings the application for renewal of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)  
Director

23/01/2024