

938

JFA

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2024/ School | 34

Dated: - 30/01/2024

To,

The Principal,  
S.K.R. Public School,  
Bohrianwala Thalla, Inderpuri, New Delhi - 110012.

**Subject: Renewal of Fire Safety Certificate in r/o S.K.R. Public School Located at Bohrianwala Thalla, Inderpuri, New Delhi - 110012.**

Sir,

Please refer to your letter No. nil dated 02/01/2024 on the subject mentioned above. In this connection it is to inform you that the premises re-inspected by the officer concerned of this department on 19/01/2024 in the presence of Mr. Hemant Arora (School Employee) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Staircases found locked at terrace level.
2. Hose reel hose found removed in basement.
3. Overhead fire water tank of 6000 ltr capacity found provided against required 15000 ltr capacity.
4. Exit signage found removed at some places.
5. Basement must be used as per BBL 1983.
6. School activity also seen in dental block located in the school premises. The FSC has not been issued by this department to that block.
7. Dully fill form J & k and School details forms are not submitted.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Service

o/c  
19/1/24

Copy to; - Directorate of Education Old Secretariat Delhi - 110054.