

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F.6/DFS/MS/2024/ 178

Dated.01.02/2024

To

Sh. Pardeep Tayal,  
Deputy Secretary (GAD),  
Care Taking-I Branch,  
Level-2, A' Wing, Delhi Secretariat,  
I.P. Estate, New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in r/o Delhi Secretariat Building.

Sir,

This has reference to your letter. No. F.N. 2/1521/CTB/GAD/2018/8827 dated 11/01/24, on the subject cited above. In this connection it is to inform that the site was inspected by the officers concerned of this department on 23/01/24 in the presence of Ms. Uzma JE (E) and the following shortcomings were observed:-

1. Detector found nonfunctional at some offices and also found removed from meeting room after renovation.
2. Smoke management in basement found nonfunctional.
3. Sprinkler system required to be extended in left out areas.
4. Third floor is under renovation.
5. Electrical shaft/service shafts were not sealed properly.
6. MOEFA found not functional.
7. P.A. system was not functional.
8. Exits/Corridors should be cleared by removing of almirah and chairs dumped on the exits /corridors.

In view of above, FSC cannot be renewed. Therefore you are requested to rectify the above shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Spl. Secretary  
(Home-II),  
Govt. of National Capital Territory of Delhi.  
Home – III Department, -- for information  
5<sup>th</sup> Level, 'C' Wing, Delhi Secretariat, I.P. Estate, New Delhi.
2. The Dy. Secretary (GAD)  
2<sup>nd</sup> Level, A Wing Delhi Secretariat,  
New Delhi. – For Information
3. The Executive Engineer (E), M-253, PWD, Delhi Secretariat,  
New Delhi.