

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/2024/SZ/College/33

Dated: ..02.02/2024

To
Dr. Muhammad Abulaish,
Acting Registrar, South Asian University,
New Delhi 110068

Sub: Regarding issuance of NOC in r/o Faculty of life Science & Biotechnology & Facility of Earth Science (Academic) Building No 3 at South Asian University Complex, Maidan Garhi, New Delhi

Sir,
This has reference to your letter received through outdoor diary no 12016 dated 17/01/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 23.01.2024 in the presence of Mr. R. N Tiwari to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Automatic Fire Detection & alarming System provided but found nonfunctional.
2. Pressurization of lift well is not on auto mode.
3. Smoke management system is not on auto mode.
4. MOEFA provided but found nonfunctional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(APUL GARG)
DIRECTOR

DELHI FIRE SERVICE

du