

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2024/42

Dated: 05/02/2024

To

The Joint Commissioner of Police (Lic.),  
Police Station, Defence Colony, 1st floor,  
New Delhi- 110049.

**Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Hotel B. Continental, 8/14, WEA, Abdul Aziz Road, Karol Bagh, New Delhi- 110005.**

Sir,


Please refer to Online Application No. 2024010600156, dated 18.01.2024, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 29.01.2024 in the presence of Sh. Balbir Singh (Owner), to check the function ability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguisher, overhead water tank capacity 5,000 lts. etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Fire Check Doors are not provided.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter No. F6/DFS/MS/GH/SZ/2021/366, dated 07.09.2021, is immediately suspended. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service  
31/1/24

Copy to :-

1. The Manager, M/s. Hotel B. Continental, 8/14, WEA, Abdul Aziz Road, Karol Bagh, New Delhi- 05.