

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/ 33

Dated: 02.02/2024

To

The Manager,  
M/s La Polo and Beyond LLP,  
Ground floor at National Gallery of Modern Art,  
Jaipur house, India Gate, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S La Polo and Beyond LLP at Ground floor at National Gallery of Modern Art Jaipur House, India Gate, New Delhi.

Sir,

This has reference to Online ID No. 2024011300436 dated 13.01.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 29/01/2024 in the presence of **Manager** and following shortcomings were observed: -

1. 02 exits of 2.0 meter each are not provided.
2. Hose reel / hydrant and pump found nonfunctional.

In view of above, the case is rejected with a request to comply the same for further consideration the matter. .

Yours faithfully/

(Aftal Garg)  
DIRECTOR

Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony, Police Station, New Delhi.