

0109

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

No.F6/DFS/MS/NDZ/School/2024/ 39

Dated: 01/02/2024

To

The Principal,  
L N Girdhari Lal Senior Secondary School,  
Bagh Diwar, Fatehpuri, Delhi -06.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o L N Girdhari Lal Senior Secondary School, Bagh Diwar, Fatehpuri, Delhi -06.**

Sir,

This has reference to your letter no.1188 dated 22.12.202 received in this department, on the subject cited above. In this connection, this is to inform you that the school building was visited by officer concerned from this department on 25.01.2024 in the presence of Mr. Bishan Kaushik (Teacher) and it was observed that the building is comprised of ground + 03 upper floors, but the school is running at ground plus two upper floors. During the inspection, following shortcoming was observed:-

1. Fire extinguishers provided but non functional.
2. First aid hose reels not provided.
3. Water storage tank provided is 5,00 ltrs. against the requirement of 10,000 ltrs.
4. Fire pump of capacity 450 LPM is not provided.
5. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully

  
(Ajay Garg)  
Director

Delhi Fire Service

Tel: 011-23414000

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.

02  
23/1