

C/106

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/SZ/2024/qm/38

Dated: 01/02/2024

To,

The Addl. Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi.

**Subject: - Renewal of Fire safety Certificate in r/o M/s MSK Residency Guest House Located at C-912, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floors Ramphal Chowk, Sector-7, Dwarka, New Delhi-110077.**

Sir,

Please refer to online application No. 2024011100335, dated 15-01-2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned from this department on 19/01/2024 in the presence of Mr Kul Bhushan Sharma from fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Hose reel hose and internal hydrant found nonfunctional.
2. Automatic sprinkler system in basement found nonfunctional.
3. MOEFA found not nonfunctional.
4. Terrace pump found nonfunctional and all the valves found closed.
5. Terrace fire water tank of 5,000 ltrs capacity found empty.
6. Exit signage found removed at some places.

Applicant may be requested to comply the shortcomings under intimation with this department for further consideration in the matter

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage

Copy to: -

1. The Manager, M/s MSK Residency Guest House Located at C-912, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> Floors Ramphal Chowk, Sector-7, Dwarka; New Delhi-110077.

  
(Atul Garg)  
Director  
Delhi Fire Service  
o/c  
12/1/24