

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Industrial/2024/SZ/264

Dated: 07/02/2024

To

The Executive Engineer (Bldg.),
Building Department, MCD,
Central Zone, Jal Vihar,
Lajpat Nagar, New Delhi 1100024

Sub: Regarding issuance of Fire Safety Certificate in r/o Flatted Small Industries Building at NSIC Complex Okhla Industrial Estate, New Delhi -110020

Sir,

This is with reference to letter No SIC/HO/WD/MDC/RITES/2012/Vol.IX dated 23/01/2024 on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 31/01/2024 in the presence of Mr. Mirza Baig to verify the availability & operability of fire prevention and fire safety measures required under the rules. During the inspection following shortcoming were observed.

1. The Pressurization of Staircases, Lift Shaft & lift Lobby is non functional.
2. Smoke management system provided but found non-functional in the basement.

In view of above shortcomings, issuance of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Mr. A. Gupta (Chief Manager Works) M/s Flatted Small Industries Building, NSIC Complex Okhla Industrial Estate, New Delhi -110020