

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/GH/2024/SZ/ 37

Dated 01/02/2024

To

The Joint Commissioner of Police,
Lic / Branch, 1st floor, Police Station
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s New Heaven Guest House,
E-512, Greater Kailash Part- II, New Delhi 110048

Sir,

This has reference to with **MHA Portal ID 2024011200376 dated 12/01/2024** on the subject cited above. In this connection this is to inform you that the above mentioned premise has already been visited by the officer concerned of this department on 25/01/2024 in the presence of Ms. Pooja Vats & to verify the fire safety arrangements installed in the building. Accordingly fire safety arrangement were tested / checked and found following observations.

- 1 Smoke management system not provided in the building as per clause 7.31 of UBBL 2016.
- 2 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 3 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE