

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Mercantile/2024/SZ/35
To

Dated: 06/02/2024

The Executive Engineer (Bldg) HQ,
Municipal Corporation of Delhi,
9th floor, Civic Center, Minto Road,
New Delhi 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No R-10, Green Park Main
Local Shopping Centre, New Delhi

Sir,

This has reference with **online ID 10062868** dated **29/01/2024** on the subject cited above. In this connection, this is to inform you that joint inspection of the premise was conducted by the team of officers from Delhi Fire Service and Mr. Ashis Kumar Raj JE/Bldg/MCD on 01.02.2024 to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The Staircase communicated from basement to ground and upper floors are not segregated at ground floor as per the provision of UBBL/NBC Part IV.
2. Ventilation system in basement is not provided.
3. First aid hose reel provided but found nonfunctional.
4. MOEFA not working.
5. Internal hydrant provided but found nonfunctional.
6. Terrace level fire fighting pumps provided but found nonfunctional.
7. Terrace level fire fighting water tank is not accessible, hence the capacity could not be verified.
8. Exit signage not provided at strategic location.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

dm w