

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 31/01/2024

No. F.6/DFS/MS/2024/SZ/College/31
To

The Executive Engineer -II (Bldg) HQ,
Municipal Corporation of Delhi,
9th Floor Civic Centre, Minto Road,
New Delhi 110002.

Sub: Regarding issuance of FSC in r/o Faculty & Chemical Science & Facility of Mathematics & IT Building (Academic) Building No 4 at South Asian University Complex, Maidan Garhi, New Delhi

Sir,

This has reference to your letter no nil dated 08/12/2023, received through outdoor diary no 10659 dated 08/12/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 23.01.2024 in the presence of Sh. Vinit Goyal to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The 6 mtr wide Motorable road shall be capable to withhold the load bearing capacity of 45 tone including drainage slab cover available on the road.
2. The width of exit door is 1.50 mtr each against the required width of 2.0 mtr in the auditorium hall.
3. Smoke management provided but found not on auto mode.
4. Fire fighting arrangement & seating layout not provided in the auditorium located in the building.
5. MOEFA is not functional.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Mr. Vinit Goyal, M/s Shapoorji Pallonji & Company Pvt. Ltd, Regional office, 7, floor, Kanchenjunga Building, 18- Barakhamba Road, New Delhi 110001.