



Dated: 08/02/2024

N.F./DFS/MS/School/NDZ/2024/44

To,

The Principal,  
MCD Primary School No.01,  
Kondli Village, Delhi-110096.

**Sub: - Regarding grant of Fire Safety Certificate in r/o MCD Primary School No.01, located at, Kondli Village, Delhi-110096**

Sir,

This has a reference to your Email dated - 20.11.2023, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 30/01/2024 in the presence of Mrs. Santoshi Gudiya (Principal) and observed that building comprised of ground plus two upper floors only and following shortcomings were observed during time of inspection:

1. Fire Extinguisher not provided.
2. First-Aid-Hose Reel not provided.
3. MOEFA not provided
4. Fire pump of 450 LPM not provided.
5. Overhead tank capacity 10,000 liters not provided.
6. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Principal, MCD Primary School No.01, located at, Kondli Village, Delhi-110096.
2. The Director of Education, MCD, Udyod Sadan, Plot no.419, FIE, Patparganj Industrial Area, Delhi-110092.