

C-16

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 43

Dated: 08/02/2024

To,

The Principal,
MCD Primary CO-ED School,
Nangal Raya-I, New Delhi-110046

Sub: - Regarding renewal of Fire Safety Certificate in r/o. MCD Primary CO-ED School, Nangal Raya-I, New Delhi-110046.

Sir,

This has reference to your letter dated 19.01.2024 received through online email Id wznangarayai@gmail.com, on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on to 31.01.2024 see the compliance of the requisite fire safety measures. Ms. Shashi Bala (Principal) was present at the time of inspection.

During the course of inspection it was observed that the School building is comprised of Ground plus two upper floors. Fire safety arrangement such as hose reel, 450 LPM terrace level fire pump etc. found provided. Hence the following shortcomings were observed:-

1. Hose reel found provided but not functional.
2. Terrace fire pump capacity of 450 LPM found provided but not functional in auto mode.
3. Overhead water storage tank of 5,000 ltrs capacity found provided in place of 10,000 ltrs.

You are advised to rectify the above-mentioned shortcomings for taking further action as necessary for issuance of Fire Safety Certificate. It is further advice that email of school may also be intimated to this department for record purpose.

Yours Faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Director of Education, S.D.M.C, Civic Centre, Minto Road, New Delhi-110001