



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2024/SZ/212
To

Dated: 08/02/2024

The Executive Engineer (E)
Electrical Division No 1/DDA,
M/s Utsav Sthal Pandal,
Madangir Near Virat Cinema, New Delhi

Sub: Regarding issuance of FSC in r/o M/s Utsav Sthal Pandal at Madangir Near Virat Cinema, New Delhi

Sir,

This has reference to your letter no F3 (194)EE/(E)/ELD-11/DDA/2023-24/269 dated 18/09/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.02.2024 in the presence of Mr. Pawan Kumar (Supervisor) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel not provided.
2. MOEFA not provided.
3. Automatic sprinkler system not provided
4. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Atul Garg