

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/NDZ/2024/243

Dated:-13.02.2024

To,
The Assistant Engineer,
PWD, Health maintenance Electric Sub Division (Central),
GIPMER, GB Pant Hospital New Delhi.

Sub:- Regarding Fire clearance/renewal of "A & D" Block, GIPMER, New Delhi.

Sir,
This has reference to your letter No.10 (7)/AE(E)PWD/HC-03/2023-24/476 dated.07.12.2023, on the subject cited above. In this regard, it is to inform you that the 02 blocks of GB Pant hospital were inspected by the officers concerned of this department on 29.01.2024 in the presence of Sh. Nand Lal Gupta AE (E) & Sh. Tushar Choudhary JE (E), CPWD and the following shortcomings were still not complied.

A Block:-

1. 02 staircases found blocked by dumping of waste materials and same found locked .
2. Detection system found nonfunctional at some offices .
3. Smoke management system is not provided at upper floors.

D Block (EDP Cell):-

1. Pressurization in lift lobby & shaft found nonfunctional and work is still not completed as per norms.

Therefore, you are requested to rectify the above shortcoming immediately. Further, the occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Medical Superintendent, G.B. Pant Hospital, New Delhi.
2. The Medical Director, GIPMER, G.B. Pant Hospital, New Delhi.
3. CMO, Nodal Officer, PWD, GIPMER, G.B. Pant Hospital, New Delhi.
4. The Executive Engineer, G.B. Pant Hospital, New Delhi.