

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/Hospital/2024/NDZ/ 2 2 2

Dated:-09.02.2024

To,

The Assistant Engineer,  
Office of the Assistant Engineer HC-3,  
Health Maintenance Electrical Sub Division (Central),  
GIPMER New Delhi,  
New Delhi.

**Sub:- Regarding Fire Safety Certificate of "Academic" Block at GIPMER, New Delhi.**

Sir,

This has reference to your letter No.10(7)/AE(E)/PWD/HC-03/2023-24/492 dated 12.12.2023, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 29/01/2024 in the presence of Sh. Nand Lal Gupta AE (E) & Sh. Tushar Choudhary JE (E), CPWD and the following shortcomings are still not rectified.

1. Alternate staircases found blocked by dumping of medicine/ surgical item boxes, etc .
2. Smoke management system found nonfunctional in basement.
3. Detectors found nonfunctional in basement and at some places at upper floors.
4. Some floors are under renovation and firefighting system under installation.

In view of above shortcomings, the application of issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at risk and liability of owner/occupier. The licensing /statuary authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

**DIRECTOR**

Delhi Fire Service

Copy to:-

1. Director & Medical Superintendent, GIPMER, GB pant hospital, New Delhi.
2. Executive Engineer, Health maintenance Electrical Sub Division (Central), GB pant hospital, New Delhi.