

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/ 223

Dated: 12/02/2024

To,

Dr. Ravin Sharma, (Director),
MBBS MD Radiologist,
Ganesh Diagnostic & Imaging Centre Pvt. Ltd.
109, Pocket A-1, Near Deepali Chowk,
Sector-8, Rohini,
Delhi-110085.

Sub:- Issuance of Fire Safety Certificate for our r/o Ganesh Diagnostic & Imaging Centre Pvt. Ltd.
109, Pocket A-1, Near Deepali Chowk, Sector-8, Rohini, Delhi-110085.

Sir,

Kindly reference to online e-mail dated 16.12.2023, received in this department on the subject cited above. In this regard it is to inform you that FSC under Rule 35 of DFS Rules-2010 is issued only for those premise which are referred by Building Authority/local authority as specified in section 2 (q) of DFS Act-2007 to this department.

In this regard you are advised to first apply with concern building sanctioning authority with a request to forward following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS Rules-2010 on the said premise/building:

1. Sanctioned/Completion plans.
2. As built plans (Area, Floors, section & Elevation plans in a scale of 1:100) of the building through building/local authority, if Sanction/Completion plans are not available.
3. Occupancy of each of floors as per clause 1.4.75 of UBBL-2016 and its initial operation date.

Yours faithfully



(Atul Garg)
DIRECTOR

Ph-011-23414000

Copy to:-

1. The Executive Engineer (Bldg.), NDMC, Sector-5, Rohini, New Delhi-110085.