

C-83

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2024/ 57

Dated: 15/02/2024

To

The Joint. Commissioner of Police (Lic.),
Police Station, Defence Colony, 1st floor,
New Delhi- 110049.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Hotel Golden Grand (a unit of Sukhmani Inns Pvt. Ltd) located at W-1/10, Main Patel Road, West Patel Nagar, New Delhi-110008.

Sir,


Please refer to Online Application No. 2024020101092, dated 05.02.2024 on the subject cited above. In this connection, it is to inform you that the aforesaid guest house premises has been inspected by the officer concerned of this department on 08.02.2024 in the presence of Sh. Gurpreet Singh, Owner, to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, stilt, ground plus three upper floors. The following shortcomings were observed: -

1. Fire smoke check doors for entry to staircase at each floor level has not been provided.
2. Carban-mono-oxide detectors at all floors has not been provided.

In view of the above shortcomings, renewal of the 'Fire Safety Certificate' cannot be considered at this stage. You are requested to direct the owner/occupier to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to :-

The Owner/Occupier,
Hotel Golden Grand, W-1/10,
Main Patel Road , West Patel Nagar, New Delhi- 08