



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 40

Dated: 14/02/2024

To

Sh. Bandeeep (Auth. Signatory),
M/s Vsquare Services Pvt. Ltd,
Ansal Plaza Mall, Hudco Place,
Andrews Ganj, New Delhi-110049

Sub: Regarding issuance of Fire NOC for Basement Car Parking at Hudco Place, Andrews Ganj, New Delhi-110049

Sir,

This has reference to your letter received through outdoor diary no. 12365 dated 29/01/2024, on the subject cited above and in compliance of order of Hon'ble Delhi High Court dated 30/01/2024 in WP(C) 15918/2023, the said premise was inspected by the team of officers of this department on 06/02/2024 in the presence of Sh. Dinesh Shukla (Supervisor of VSquire). During the course of inspection, the shortcomings observed are as below.

1. Fire check doors found removed/defective.
2. The smoke management system provided but found non-functional.
3. Automatic fire detection & alarming system found non-functional.
4. MOEFA/MCPs system found removed.
5. Exit signage found removed at some places.

In view of the above shortcomings, the application for issuances of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

01/08/24