

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Hospital/2024/SZ/ 51

Dated: 15/02/2024

To
M/s Madhukar Multispecialty Hospital and Research Center,
Plot No.5, FC-29, Geetanjali,
Near Malviya Nagar Metro Station,
Gate No.1, New Delhi-110017.

Sub: Regarding issuance of FSC in r/o M/s Madhukar Multispecialty Hospital and Research Center, Plot No.5, FC-29, Geetanjali, Near Malviya Nagar Metro Station, Gate No.1, New Delhi-110017.

Sir,
This has reference to your letter received through Outdoor diary No 7534 dated 18/10/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 09.02.2024 in the presence of Mr. Kuldeep Sharma to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Pressurization system staircases & lift lobby not working.
2. Smoke management system is not on auto mode.
3. Refuse area not provided.
4. Temporary structure seems at terrace level which is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

D/W